



EKO®5-1-12, Fire Extinguishing Agent

Certificate Number: **FM24US0063**

Company

KLENTS LLC

400 Rella Blvd Ste. 207-111, Montebello, New York 10901

United States of America

<http://www.klents.com>

Fixed Extinguishing Systems | Clean Agents | **Clean Extinguishing Agents**

EKO®5-1-12, Fire Extinguishing Agent

Description of Equipment:

Trade Name:	EKO®5-1-12, Fire Extinguishing Agent
Chemical Identification:	dodecafluoro-2-methylpentan-3-one, $\text{CF}_3\text{CF}_2\text{C}(\text{O})\text{CF}(\text{CF}_3)_2$
Designation:	FK-5-1-12
Minimum Extinguishing Concentrations:	Class A – 3.35% Class B – 4.5%
ALC	>10%
NOAEL:	10%
LOAEL:	>10%
Uses:	For use in FM Approved fire extinguishing systems that have been tested expressly for use with FK-5-1-12 agent. Class A (surface burning only), Class B, and Class C extinguishing capabilities.

Details

Category	Clean Extinguishing Agents
Class of Work	5600 - Exting Sys, Clean Agent
Certification Type	FM Approved
Agent Type	FK-5-1-12
Certificate Number	FM24US0063
Listing Country	United States of America